



1 Main Mezz Plan
SCALE 1/8" = 1'-0"

INTERIOR WALL TYPES

- P1** 8' CORRIDOR WALLS -
1 LAYER 5/8" TYPE X GYPSUM BOARD
2 X 4 STUDS STAGGERED @ 16" O.C.
ON 2 X 4 PLATES TOP AND BOTTOM
1 LAYER OF SOUND ATTENUATION BATT INSULATION
2 LAYERS 5/8" TYPE X GYPSUM BOARD
1 HR FIRE RATED WALL ASSEMBLY BCBC U3c STC 54
- P2** 2' PARTY WALL -
1 LAYER 5/8" TYPE X GYPSUM BOARD
2 X 4 STUDS STAGGERED @ 16" O.C.
ON 2 X 4 PLATES TOP AND BOTTOM
3-3/4" AIR SPACE 2 X 4 STUDS @ 16" O.C.
ON 2 X 4 PLATES TOP AND BOTTOM
1 LAYER OF SOUND ATTENUATION BATT INSULATION
1 LAYER 5/8" TYPE X GYPSUM BOARD
1 HR FIRE RATED WALL ASSEMBLY BCBC U3c STC 54
- P3** 8' PARTY WALL -
1 LAYER 5/8" TYPE X GYPSUM BOARD
2 X 4 STUDS @ 16" O.C.
ON 2 X 4 PLATES TOP AND BOTTOM
1" AIR SPACE 2 X 4 STUDS @ 16" O.C.
ON 2 X 4 PLATES TOP AND BOTTOM
1 LAYER OF SOUND ATTENUATION BATT INSULATION
1 LAYER 5/8" TYPE X GYPSUM BOARD
1 HR FIRE RATED WALL ASSEMBLY BCBC U3c STC 54
- P4** INTERIOR PARTITION - NON LOAD BEARING
1 LAYER 1/2" GYPSUM BOARD
2 X 4 STUDS @ 16" O.C.
ON 2 X 4 PLATES TOP AND BOTTOM
1 LAYER 1/2" GYPSUM BOARD
- P5** SUITE - ELEVATOR SHAFT
1 LAYERS 5/8" TYPE X GYPSUM BOARD
RESILIENT HURRING CHANNELS @ 16" O.C.
1-1/2" ARXK WALL SYSTEM WITH 6" CONCRETE CORE
1 HR FIRE RATED WALL ASSEMBLY BCBC U3c STC 54
- P6** INTERIOR WALL - LOAD BEARING
1 LAYER 1/2" GYPSUM BOARD
2 X 4 STUDS @ 16" O.C.
2-2 X 4 TOP PLATES
2-2 X 4 BOTTOM PLATES
1 LAYER 1/2" GYPSUM BOARD
- P7** ARXK PARTY WALL -
1 LAYER 5/8" TYPE X GYPSUM BOARD
1-1/2" ARXK WALL SYSTEM WITH 6" CONCRETE CORE
1 LAYER 5/8" TYPE X GYPSUM BOARD
- P8** SHAFT WALL -
1 LAYER 5/8" TYPE X GYPSUM BOARD
1-1/2" ARXK WALL SYSTEM WITH 6" CONCRETE CORE
1 LAYER 5/8" TYPE X GYPSUM BOARD
- P9** STORAGE ROOM PARKADE
1 LAYER 5/8" TYPE X GYPSUM BOARD
2-5/8" STEEL STUDS @ 16" O.C.
1 LAYER 5/8" TYPE X GYPSUM BOARD
1 HR. RATED ASSEMBLY
- P10** PARKADE
8" CONCRETE BLOCKWORK
PAINTED
1 HR. RATED ASSEMBLY
- P11** 4" CORRIDOR WALL -
1 LAYER 5/8" TYPE X GYPSUM BOARD
2 X 4 STUDS @ 16" O.C.
ON 2 X 4 PLATES TOP AND BOTTOM
1 LAYER OF SOUND ATTENUATION BATT INSULATION
1 LAYER 5/8" TYPE X GYPSUM BOARD
1 HR FIRE RATED WALL ASSEMBLY BCBC U3c STC 54
- P12** 12' PARTY WALL -
1 LAYER 5/8" TYPE X GYPSUM BOARD
2 X 4 STUDS @ 16" O.C.
ON 2 X 4 PLATES TOP AND BOTTOM
1" AIR SPACE
1 LAYER OF SOUND ATTENUATION BATT INSULATION
2 X 4 STUDS @ 16" O.C.
ON 2 X 4 PLATES TOP AND BOTTOM
1 LAYER 5/8" TYPE X GYPSUM BOARD
1 HR FIRE RATED WALL ASSEMBLY BCBC U3c STC 54

NOTE: PLATFORM FRAME ALL CONSTRUCTION TO EACH FLOOR LEVEL INCLUDING ALL MEZZANINE LEVELS.

RECEIVED
NOV 28 2003
CITY OF VICTORIA
PERMITS & INSPECTIONS DIVISION

N.B.
27/11/03

Nicholas Bawf Architect 648 Battery Street, Victoria, BC, V8V 1E9 phone / fax : 250 364 0971 e-mail : nba@nba.com	The Wing Proposed Multi Family Residential Development Phase 1 100 & 105 Wilson Street, Victoria, B.C.	SHEET TITLE MEZZANINE PLAN	SHEET NO. A2.2
		DRAWN N. Bawf	DATE 24.11.03